



Certificate number: 2507716 (1)

Issued 03/07/2025

Expires 03/07/2030

## Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

### Horne Engineering Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

**Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.**

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory  
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec  
(A Trading Division of Kiwa Ltd)  
26A Rassau Industrial Estate  
Ebbw Vale  
Gwent  
NP23 5SD  
United Kingdom  
T +44 (0)1495 308185  
[uk.water@kiwa.com](mailto:uk.water@kiwa.com)  
[www.kiwa.co.uk](http://www.kiwa.co.uk)

**Certificate Issued to:**  
Horne Engineering Ltd  
Rankine Street  
Johnstone  
Renfrewshire  
PA5 8BG  
United Kingdom



KUKreg4

# Product Certificate

Appendix to Certificate number: 2507716

---

The following products belong to this certificate

<b>PRODUCT DESCRIPTION</b> Inline thermal disinfection unit comprising of a manual diverter incorporating two spherical valve controlling the flow of the cold and hot water. ATS3 – Without Production Surveillance.
<b>MODEL(S)</b> ILTDU
<b>SIZE:</b> 15mm compression.
<b>SCOPE:</b> Manufacturer recommended maximum working pressure 10 Bar & maximum operating temperature 85°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C.
<b>MARKING</b> Horne, flow arrows, hot cold, website address, UK part No and Patent information on plate.
<b>MATERIALS</b> Non-metallic materials assessed (BS6920) to point of discharge.
<b>BACKFLOW PROTECTION NOTES</b> N/A.
<b>ADDITIONAL NOTES</b> All water contact & exposed components satisfy opacity requirements.

## Extra Notes